

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50472362

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

05-hehenr-50334246 001

03.07.2020

(day/mo/yr)

Genehmigungsinhaber *License Holder*

ShenZhen Cisconn Electronics CO.,LTD
5 / F, Building 6, Qiaotou Community
Industrial City, Fuyong Street,
Bao'an District, Shenzhen
518103 Guangdong
P.R. China

Fertigungsstätte *Manufacturing Plant*

Huizhou cisconn Electronics CO.,LTD
4 / F, building C,
junxingfa Science Park,
Baishi Village, Qiuchang Town,
Huiyang District, Huizhou City
516221 Guangdong
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 61984:2009

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

Connector (Electrical Connector)

| | | | |
|-------------------|---------------------|---------------------|----|
| Type Designation: | G0309-120F00-6M2-0H | G0309-120M00-6F2-0H | 15 |
| | G0618-120F00-6M2-0H | G0618-120M00-6F2-0H | |
| | G0318-120F00-6M2-0H | G0318-120M00-6F2-0H | |
| | G0300-120F00-6M3-0H | G0300-120M00-6F3-0H | |
| | G0600-120F00-6M3-0H | G0600-120M00-6F3-0H | |
| | G0309-120F00-6M1-0H | G0309-120M00-6F1-0H | |
| | G0316-120F00-6M1-0H | G0316-120M00-6F1-0H | |

Trademark : cisconn
Rated Voltage : 250 VAC(power) 120 VAC(signal)
Rated Current : 20A (power) 0.5A (signal)
Ambient Temperature : -40°C - +50°C
Lower Limiting Temperature : -40°C
Upper Limiting Temperature : 125°C
Pollution Degree : 2
Overvoltage Category : II
Protection Degree : IP20

Remark: The installation has to be carried out according to installation instruction accompanying the products.

15

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



ShenZhen Cisconn Electronics
CO.,LTD
Guowen Lu General manager

Date : 03.07.2020
Our ref. : hehenr 05
Your ref.:

5 / F, Building 6, Qiaotou
Community
Industrial City, Fuyong Street,
Bao'an District, Shenzhen
518103 Guangdong

Ref : R TÜV-Mark Approval

Type of Equipment : Electrical Connector
Model Designation : See Certificate
Certificate No. : R 50472362 0001
Report No. : 50334246 001

Dear Guowen Lu,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body

G. Yin

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询